

Measure Guidelines for EnergySmart Grocer (ESG)





Measure Guidelinesfor EnergySmart Grocer (ESG)

Table of Contents Pag	е
Cases 1. Low Temperature Open Case to New Reach-in 2. Medium Temperature Open Case to New Reach-in 3. Low Temperature Coffin to New High-Efficiency Reach-in 4. Standard Doors to Low/No Anti-Sweat Heat Doors for Low Temperature Reach-in 5. No Doors to Doors. 6. Add Lids to Open Medium Temperature Coffin Cases 7. Add Lids to Open Low Temperature Coffin Cases 8. Add Lids to Self-Contained Open Medium Temperature Coffin Cases 9. Add Lids to Self-Contained Open Low Temperature Coffin Cases	1 2 3 3 4 4
Controls 10. Anti-fog film	5 5 6
Strip Curtains 15. Strip Curtains for Walk-in Boxes	7
Night Covers 16. Night Covers for Vertical Open Cases	7
Motors 17. Shaded Pole Fan Motor to ECM in Display Cases. 18. Shaded Pole to ECM in Walk-in 19. Shaded Pole to Permanent Magnet Synchronous Motor 20. Motors Mixed Baseline – Shaded Pole and Electronically Commutated Motors to Permanent Magnet Synchronous Motor in Display Cases 21. PSC to ECM in Display Cases 22. PSC to ECM in Walk-in Evaporator 23. VFD on Condenser Fan Motor.	8 8 8 9
Condensers & Compressors 24. Reduced Head Pressure for Multiplex Compressor System	0 0 11
Controlled Equipment 29. On-Demand Hand Wrappers	

Cases

1. Low Temperature Open Case to New Reach-in

Must replace an existing low temperature open vertical display case with a new low temperature high-efficiency reach-in case.

Existing Equipment Requirements	Replacement Equipment Requirements
T-8/10/12 lamps	LED lamps listed on the Mass Save® Interim Pre-Qualified LED Fixture List or DesignLights Consortium® (MassSave.com/Business or designlights.org).
No doors	Glass doors
Shaded pole fan motors/ECM	ECM fan motors

Exclusions: Refurbished cases are not eligible for incentive; replacement case must be new and have zero in-service hours.

New case length must be equal to or shorter than original case.

Recommendations: Customer should consider using compressor capacity modulation mechanisms (such as VFDs, cylinder un-loaders, evaporator pressure regulating valves and re-setting to higher suction pressures/temperatures). If heated doors are installed with the new case, it is recommended that anti-sweat heater controls are utilized (see measure #8) for additional energy savings and an incentive opportunity.

If no/low heat doors are installed with the new LT case, then an additional incentive is available (see measure #5).

Units: Linear feet of case

2. Medium Temperature Open Case to New Reach-in

Must replace an existing medium temperature open vertical display case with a new high-efficiency reach-in case.

Existing Equipment Requirements	Replacement Equipment Requirements
T-8/10/12 lamps	LED lamps listed on the Mass Save Interim Pre-Qualified LED Fixture List or DesignLights Consortium (MassSave.com/Business or designlights.org).
No doors	Glass doors
Shaded pole fan motors/ECM	ECM fan motors

Exclusions: Refurbished cases are not eligible for incentive; replacement case must be new and have zero in-service hours. New case length must be equal to or shorter than original case.

Recommendations: Customer should consider using compressor capacity modulation mechanisms (such as VFDs, cylinder un-loaders, evaporator pressure regulating valves and re-setting to higher suction pressures/temperatures). If heated doors are installed with the new case, it is recommended that anti-sweat heater controls are utilized (see measure #8) for additional energy savings and incentive.

Units: Linear feet of case

3. Low Temperature Coffin to New High-Efficiency Reach-in

Must replace an existing low temperature reach-in or coffin case with a new high-efficiency reach-in case.		
Existing Equipment Requirements	Replacement Equipment Requirements	
Open coffin case	LED lamps listed on the Mass Save Interim Pre-Qualified LED Fixture List or DesignLights Consortium (MassSave.com/Business or designlights.org).	
	Low/no anti-sweat heat glass doors (see measure #5) » Triple pane glass door. » Anti-sweat heat in door rail, glass, and frame must be ≤0.39 amps/ln ft of case at 120 volts. » Doors must prevent condensation from occurring in the frame assembly.	
Shaded pole or ECM fan motors	ECM fan motors	
	in cases must be equal to or shorter than 1/3 the original case length. ntive; replacement case must be new and have zero in-service hours.	
	nsider using compressor capacity modulation mechanisms (such as VFDs, regulating valves and re-setting to higher suction pressures/temperatures).	
Units: Linear feet of case		

4. Standard Doors to Low/No Anti-Sweat Heat Doors for Low Temperature Reach-in

Must replace an existing standard glass door of a low temperature reach-in or walk-in reach-in display case with a low/no anti-sweat heat glass door.

Pre-Retrofit Requirements	Post-Retrofit Requirements
Glass door	Triple pane glass door
Anti-sweat heat >0.39 amps/In ft of case at 120 volts	Anti-sweat heat in door rail, glass, and frame must be ≤0.39 amps/ln ft of case at 120 volts.
	Doors must prevent condensation from occurring in the frame assembly.
Units: Linear feet of case	

5. No Doors to Doors

Must add glass doors to an existing open vertical medium temp display case.	
Existing Equipment Requirements	Replacement Equipment Requirements
T-8/10/12 lamps or LEDs	LED lamps listed on the Mass Save Interim Pre-Qualified LED Fixture List or DesignLights Consortium (MassSave.com/Business or designlights.org).
No doors	No heat doors

Exclusions: Retrofitted door must not have anti-sweat heat in the door, rail, or frame. Not applicable to wet rack cases or integral cases.

Additional Requirements: Must replace thermal expansion valves on cases receiving doors. Refrigeration load will be reduced as a result of adding doors to cases. Must consult with refrigeration contractor to make any additional adjustments to refrigeration system capacity control as needed.

Notes: Standard power LED lighting refers to lighting fixtures with a power consumption between 4 W/ft of luminaire and 2.5 W/ft of luminaire.

Low-power LED lighting refers to lighting fixtures with a power consumption less than 2.5 W/ft of luminaire "French" doors are a configuration of two reach-in doors that swing open away from the center interface between the two doors. French style doors do not have a traditional mullion; instead they have overlapping gasket material that creates a temporary seal when the two doors are closed. French doors typically have lighting on the doors next to the hinges, and along the top door frame.

Units: Linear foot of case

6. Add Lids to Open Medium Temperature Coffin Cases

Must install glass lids to an existing open medium-temperature coffin display case.		
Existing Requirements	Replacement Equipment Requirements	
Medium temperature case	Medium temperature case	
No lids	No-heat lids	
Exclusions: The existing open case might have anti-sweat heaters, but the retrofitted lids must not have glass anti-sweat heat. Not applicable to integral/self-contained cases.		
Recommendations: Customer should consider raising the case temperature setpoint by 3°F to 6°F.		
Units: Linear feet of case		

7. Add Lids to Open Low Temperature Coffin Cases

Must install glass lids to an existing open low-temperature coffin display case.		
Existing Requirements	Replacement Equipment Requirements	
Low temperature	Low temperature	
No lids	No-heat lids	
Exclusions: The existing open case might have anti-sweat heaters, but the retrofitted lids must not have anti-sweat heat in the doors. Not applicable to integral cases.		
Recommendations: Customer should consider raising the case temperature setpoint by 3°F.		
Units: Linear feet of case		

8. Add Lids to Self-Contained Open Medium Temperature Coffin Cases

Must install glass lids to an existing self-contained open medium-temperature coffin display case.		
Existing Requirements	Replacement Equipment Requirements	
Self-contained, medium temp	Self-contained, medium temp	
No lids	No-heat Lids	
Exclusions: The existing open case might have anti-sweat heaters, but the retrofitted lids must not have glass anti-sweat heat. Applicable to integral/self-contained cases only.		
Units: Linear feet of case		

9. Add Lids to Self-Contained Open Low Temperature Coffin Cases

Must install glass lids to an existing open low-temperature coffin display case.		
Existing Requirements	Replacement Equipment Requirements	
Self-contained, low temperature	Self-contained, low temperature	
No lids	No-heat lids	
Exclusions: The existing open case might have anti-sweat heaters, but the retrofitted lids must not have glass anti-sweat heat. Applicable to integral/self-contained cases only.		
Units: Linear feet of case		

Controls

10. Anti-fog Film

Must install film that prevents fogging when a door is opened and maintains clear visibility of the product, eliminating the need for electric heat.

the need for electric heat.	
Pre-Retrofit Requirements	Post-Retrofit Requirements
Low temperature (lower than 32°F) reach-in display cases	Application of film to inside of glass door
Anti-sweat heat applied to glass doors	Disconnection of power to door heat circuit
	Placement of note in area of heat circuit disconnection explaining that "Glass heat has been disabled per Rhode Island Energy energy efficiency project # on [date]"
Exclusions: Low/No heat doors	
Units: Square Ft	

11. Anti-Sweat Heater (ASH) Controls

Must install a device that controls the ASH load of reach-in doors. This measure is relevant for both MT and LT reach-in glass door cases.

Pre-Retrofit Requirements	Post-Retrofit Requirements
Medium Temperature Case Uncontrolled ASH present >0.20 amps/ft of case (door rail, glass and/or frame heating element combined)	Must automatically modulate heater output based on environmental conditions (temperature or relative humidity) as measured by a sensor that is part of the control system.
Low Temperature Case Uncontrolled ASH present >0.39 amps/ft of case (door rail, glass and/or frame heating element combined)	Must automatically modulate heater output based on environmental conditions (temperature or relative humidity) as measured by a sensor that is part of the control system.

Additional Information: If there is no amp tag to determine the door amps for the base case, please call ESG staff to help qualify the case or door frame.

Units: Linear feet of case

12. Anti-Sweat Heater (ASH) Micropulse Controls to Walk-in Reach-in Cases

Must install a device that controls the ASH output of walk-in reach-in (WIRI) doors. This measure is relevant for both MT and LT WIRI glass doors.

Existing Requirements	Post-Retrofit Requirements
Medium Temperature Case Uncontrolled ASH present >0.20 amps/ft of case (door rail and/or frame heating element combined)	Must install a device that automatically controls the ASH to run at pulsed output based on door humidity level.
Low Temperature Case Uncontrolled ASH present >0.39 amps/ft of case (door rail and/or frame heating element combined)	Must install a device that automatically controls the ASH to run at pulsed output based on door humidity level.

Additional Information: If there is no amp tag to determine the door amps for the base case, please call ESG staff to help qualify the case or door frame.

Units: Linear feet of case

13. Anti-Sweat Heater (ASH) ON/OFF Controls to Walk-in Reach-in Cases

Must install a device that controls the ASH output of walk-in reach-in (WIRI) doors. This measure is relevant for both MT and LT WIRI glass doors.

and Li Wiki glass doors.	
Existing Requirements	Post-Retrofit Requirements
Medium Temperature Case Uncontrolled ASH present >0.20 amps/ft of case (door rail and/or frame heating element combined)	Must install a device that automatically turns the ASH on and off based on door humidity level.
Low Temperature Case Uncontrolled ASH present >0.39 amps/ft of case (door rail and/or frame heating element combined)	Must install a device that automatically turns the ASH on and off based on door humidity level.
Additional Information: If there is no amp tag to determine the door amps for the base case, please call ESG staff to	

Additional Information: If there is no amp tag to determine the door amps for the base case, please call ESG staff to help qualify the case or door frame.

Units: Linear feet of case

14. Walk-in Evaporator Fan Control – ECM – Low & Medium Temperature

Must install controls that reduces or turns off fan speed when there is no refrigerant being delivered to the evaporator.	
Existing Equipment Requirements	Replacement Equipment Requirements
Electronically commutated motor (ECM)	Same
Evap fan motor size (nameplate rated output power): 1/20th HP to 1/10th HP	Evap fan motor size (nameplate rated output power): 1/20th HP to 1/10th HP
Evap fan full speed runtime: full speed 24hrs/day except if off for defrost periods	Evap fan full speed runtime: full speed only during call for cooling (compressor on or liquid-line solenoid open).
From four full on a skill FFO DDM	Evap fan full speed: 1,550 RPM
Evap fan full speed: 1,550 RPM	Evap fan low speed: 500-600 RPM
	Alternative to low speed: On/off cycling. During periods when there is no refrigerant being delivered to the evaporator, eligible controllers may cycle the fans off only if they turn the fans on periodically during that time to circulate air in the walk-in (not more than 1 minute every 8 minutes or 13% of time).

Exclusions: On walk-in refrigeration circuits served by multiplex systems, liquid-line solenoid is required for adequate control; multiplex systems without liquid-line solenoid on the walk-in circuit are not eligible at this time.

Units: Motor controlled

Strip Curtains

15. Strip Curtains for Walk-in Boxes

Must install new strip curtains or plastic swinging doors on walk-in doorways of refrigerated spaces.	
Pre-Retrofit Requirements Post-Retrofit Requirements	
No strip curtains installed	Strip curtains ≥0.06 inches thick
	Low temp strip curtains must be used on low temp applications.
Units: Square feet of doorway (measured inside door frame)	

Night Covers

16. Night Covers for Vertical Open Cases

Must install a cover on an otherwise open display case to decrease cooling load of the refrigerated case during off-hours.		
Existing Equipment Requirements	Replacement Equipment Requirements	
No night cover installed	Night covers installed and be applied for a period of at least six hours in each 24-hour period.	
Recommendations: It is recommended that these film type covers have small, perforated holes to decrease moisture buildup.		
Units: Linear foot of night cover		

Motors

17. Shaded Pole Fan Motor to ECM in Display Cases

Applicable to existing shaded pole evaporator fan motors in refrigerated display cases.	
Pre-Retrofit Requirements Post-Retrofit Requirements	
Shaded pole motor in display case	Electronically commutated motor (ECM) in display case
Units: Motor	

18. Shaded Pole to ECM in Walk-in

Applicable to existing shaded pole evaporator fan motors in refrigerated display cases.		
Pre-Retrofit Requirements	Post-Retrofit Requirements	
Shaded pole motor in display case	Electronically commutated motor (ECM) in walk-in evaporator	
Additional notes: Not applicable to controlled shaded pole motors.		
Recommendations: This measure may be combined with "Walk-in Evaporator Fan Control – ECM" measure for additional energy savings and incentive (see measure #14).		
Units: Motor		

19. Shaded Pole to Permanent Magnet Synchronous Motor

Applicable to existing shaded pole evaporator fan motors for refrigerated display cases.	
Pre-Retrofit Requirements	Post-Retrofit Requirements
Shaded pole motor in display case	Permanent magnet synchronous motor
Units: Motor	

20. Motors Mixed Baseline — Shaded Pole and Electronically Commutated Motors to Permanent Magnet Synchronous Motor in Display Cases

Applicable to existing shaded pole and ECM evaporator fan motors for refrigerated display cases.		
Pre-Retrofit Requirements	Post-Retrofit Requirements	
Mixture* of shaded pole motor and ECMs in display case	Permanent magnet synchronous motor	
Units: Motor		

^{*}ECM motor retrofit projects should contain at least 25% shaded pole motors being retrofitted at the same time for ECMs to qualify for incentive.

21. PSC to ECM in Display Cases

Applicable to existing shaded pole evaporator fan motors for refrigerated display cases.	
Pre-Retrofit Requirements Post-Retrofit Requirements	
Permanent split capacitor (PSC) motor in display case	Electronically commutated motor (ECM)
Units: Motor	

22. PSC to ECM in Walk-in Evaporator

Applicable to existing shaded pole evaporator fan motors for refrigerated display cases.	
Pre-Retrofit Requirements Post-Retrofit Requirements	
Permanent split capacitor (PSC) motor in walk-in evaporator	Electronically commutated motor (ECM)
Exclusions: Not applicable to controlled shaded pole motors.	

23. VFD on Condenser Fan Motor

Must install variable frequency drive (VFD) on condenser fan motors.		
Pre-Retrofit Requirements Post-Retrofit Requirements		
No VFD present	All condenser fan motors controlled via VFD	
Exclusions: Cannot be combined with measures that require a VFD.		
Units: Motor nameplate horsepower		

Condensers & Compressors

24. Reduced Head Pressure for Multiplex Compressor System

Must lower the fixed head pressure setting of an existing multiplex system.	
Pre-Retrofit Requirements	Post-Retrofit Requirements
Fixed head pressure >70°F	Fixed head pressure <70°F
Units: Compressor nameplate horsepower	

25. Floating Head Pressure Controls

Must convert the head pressure controls of an existing multiplex system from fixed control to floating control.	
Pre-Retrofit Requirements	Post-Retrofit Requirements
Fixed head pressure >70°F	Floating head pressure at or below 70°F
	Air-cooled condensers Must maintain an ambient following condensing setpoint of 15°F temperature differential (TD) or less between the outside air drybulb temperature and the setpoint. Either use a variable speed drive or assume no change in fan operation. If a variable frequency drive is used it must control all condenser fans in parallel, unless the controls sequence receives pre-approval by ESG.
	Evaporative-cooled condensers Must maintain a wetbulb following setpoint of 17°F TD or less between the outside air wetbulb temperature and the setpoint. Must be controlled with a variable speed drive or two-speed fan control.
Notes: TD setting should be chosen base ambient conditions while also allowing the	d on the system design to allow the head pressure to float down during low the fans to cycle off or ramp down.
Units: Multiplex compressor nameplate h	orsepower

26. Floating Suction Pressure Controls

Must convert the suction pressure controls of an existing multiplex system from fixed control to floating control.		
Pre-Retrofit Requirements	Post-Retrofit Requirements	
Fixed suction pressure set point	Floating suction pressure	
	Suction pressure must be adjusted to the highest point that can still maintain setpoint temperatures at monitored cases on the suction circuit. Must be programmed to float at least 3 PSI.	
Units: Multiplex compressor nameplate horsepower		

Condensers & Compressors (continued)

27. High-Efficiency Multiplex Compressor System – Custom Measure

Must replace a standalone compressor system with a high-efficiency multiplex compressor system.

Below are recommendations, but not requirements for this custom measure. An engineering review of the proposed design is required to determine energy efficiency, incentive eligibility and incentive amount.

Pre-Retrofit Requirements	Post-Retrofit Requirements
Standalone compressor system	High-efficiency multiplex compressor system
Air-cooled condenser – fixed pressure head	Floating head pressure controls, air-cooled condensers: Staged fans or variable speed drive. Ambient following condensing setpoint of 10°F temperature differential (TD) or less between the outside air drybulb temperature and the setpoint for low temperature systems, and a 15°F TD or less for medium temperature systems. When a single circuit condenser is used, a 10°F TD or less is advised. Minimum saturated condensing temperature equal to or less than 70°F.
Evaporative-cooled condenser – fixed pressure head	Floating head pressure controls, evaporative-cooled condensers: Fans controlled by variable speed drive. Wetbulb following setpoint of 25°F TD or less between the outside air wetbulb temperature and the setpoint. Minimum saturated condensing temperature equal to or less than 70°F.

28. Efficient / Oversized Air or Evaporative Condenser for Multiplex – Custom Measure

Must replace an existing condenser with a new efficient/oversized condenser.

Below are recommendations, but not requirements for this custom measure. An engineering review of the proposed design is required to determine energy efficiency, incentive eligibility and incentive amount.

Pre-Retrofit Requirements	Post-Retrofit Requirements
Existing condenser	Efficient/oversized condenser
Air-cooled condenser – fixed pressure head	Floating head pressure controls, air-cooled condensers: Stage fans or variable speed drive Ambient following condensing setpoint of 8°F temperature differential (TD) or less between the outside air drybulb temperature and the setpoint for low temperature systems, and a 13°F TD or less for medium temperature systems. When a single circuit condenser is used, a 8°F TD or less is advised. Minimum saturated condensing temperature equal to or less than 70°F. Specific energy efficiency of condenser greater than or equal to 85 BTU/hr/W when calculated at the design TD.
Evaporative cooled condenser – fixed pressure head	Floating head pressure controls, evaporative-cooled condensers: Fans controlled by variable speed drive. Wetbulb following setpoint of 25°F TD or less between the outside air wetbulb temperature and the setpoint. Minimum saturated condensing temperature equal to or less than 70°F.

Controlled Equipment

29. On-Demand Hand Wrappers

Must replace an existing hand wrapper with instant on and instant heat hand wrapper.		
Existing Equipment Requirements	Replacement Equipment Requirements	
Hand wrapper without occupancy sensors	Hand wrapper with occupancy sensors that remain energized only during the sealing process and power down when not in use.	
Existing units must be removed from store.		

30. Destratification Fans

Must install destratification fans underneath the ceiling at a minimum height of 15 feet.		
Existing Requirements	Replacement Equipment Requirements	
No destratification device	Destratification fans installed at a minimum height of 15 feet	
Exclusions: The destratification fans must not be high-volume high-speed fans.		
Additional Requirements: Space must be heated by natural gas forced-air heating systems, including unit heaters and have floor-level thermostat temperature controls.		
Units: Quantity of fans		

31. Efficient Hand Dryers

Must install efficient hand dryers that save energy by drying with air movement, using motion sensors, and reducing drying time.

Equipment Requirement

Any hand dryer with a rated per-use energy consumption of 5 Watt-hours or less, installed in a restroom in a grocery or restaurant.

Units: Hand dryer

Refrigeration Retrofits

"Low temperature" covers evaporator temperatures below 0°F.

"Medium temperature" covers evaporator temperatures between 1°F and 35°F.

These guidelines are subject to change without notice.

Please check with your Account Manager to confirm that your proposed installation meets requirements or or call 1-888-683-0483 to contact an EnergySmart Grocer representative. If you have a custom measure that yields equal or greater energy savings, you may request an engineering review to determine whether it qualifies for an incentive.